

Conformity of Product: Executive Range	Creation Date	Version	Page
	03/01/2013	1.3	1 of 1
Owner	Revision Date	Review Date	Reviewed by
Mark Brookes	31/3/2009	31/03/2014	MBr

This is to confirm that the product range:

Chubbsafes Executive Cabinet

is certified to fire resistance class NT 017 – 60 Paper in sizes:

15 KL (1109002100), 25 KL (1109002101), 40 KL (1109002102), 65 KL (1109002103), 15 EL (1109002110), 25 EL (1109002111), 40 EL (1109002112) and 65 EL (1109002113)

In accordance with NT Fire 017 and SP's certification rules for fire resisting storage cabinets, SPCR 002.

Certification is issued by:
SP Technical Research Institute of Sweden
SP Box 857
SE-501 15 Borås
Sweden

The original certificate number is 38 27 01 based upon the findings of certification report number C 7/2004.

Certification extended for the fourth time following original certification 2nd of April 2004

Certification Expiry date: March 31st 2014

All manufacturing processes are under surveillance by SP in accordance with section 4 and 5 of SPCR 002. Other terms and conditions are set out in section 6 of SPCR 002.



Mark Brookes
Product Manager

Gunnebo AB
% Gunnebo UK Ltd
Wolverhampton

Gunnebo UK Limited

Fairfax House
Pendeford Business Park
Wobaston Road
Wolverhampton
WV9 5HA
United Kingdom

Phone: +44 (0) 1902 455 111
Fax: +44 (0) 1902 351 961

www.gunnebo.com